



1090 Bristol Road
Mountainside, NJ 07092
(908) 654-8068
(800) 783-0567
Fax 908-654-8069

LEAD IN DRINKING WATER REPORT

Performed At:

Gillette Elem School-759 Valley Road-Gillette NJ
Millington Elem School-91 Northfield Road-Millington NJ
Central Middle School-90 Central Avenue-Stirling NJ

Performed For:

The Long Hill Township Board of Education
759 Valley Road
Gillette, NJ 07933

Prepared By:

LEW Corporation
1090 Bristol Road
Mountainside, NJ 07092

Phone (908) 654-8068
Fax (908) 654-8069
Website <http://www.LEWCorp.com>


Inspection Date: 12/29/2016
Project Number: 160955

Contact Information

Agency

Client Contact:	John Esposito
Client Name:	The Long Hill Township Board of Education
Street Address:	759 Valley Road Gillette, NJ 07933
Phone Number:	(908) 647-1200 x1035

Risk Assessor(s)

Site Assessor(s):	Raheen Holland
License:	NJDOH #013217
Signature:	
Date:	January 30, 2017
E-Mail:	Rholland@lewcorp.com

Firm

Organization:	LEW Corporation
Certification #:	NJDCA 00015 E
Street:	1090 Bristol Road
City, State & Zip:	Mountainside, New Jersey 07092
Phone Number:	908-654-8068
Web Address:	http://www.lewcorp.com

Laboratory

Organization:	National Testing Laboratories, Ltd
Street:	556 Mansfield St.
City, State & Zip:	Ypsilanti, MI 48197
NJDEP Certification #	MI859
Phone Number:	804-353-6778

Introduction

LEW Corporation was contracted by The Long Hill Township Board of Education to test for the presence of lead in drinking water in six schools in the district.

Sampling Methodology

LEW Corporation followed the July 13, 2016 amendments to NJAC 6A:26. Full details on sampling practices can be found in Districts Sampling Plan.

All samples were collected in 250mL wide mouth plastic containers that was prepackaged by the analytical laboratory. The sample containers may contain nitric acid, if expedited analysis is required. If not, nitric acid will be added to each sample upon arrival at the laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours. If second draw samples were collected, they were collecting following a flushing protocol outlined in the District's Sampling Plan.

Long Hill TWP Public School Water Sampling All Results

ND=None Detected

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Gillette Elementary	12/29/2016	1/7/2017	759-1	Room #13-S -1st Draw	4.00
Gillette Elementary	12/29/2016	1/6/2017	759-2	Nurse Office-NS-1st Draw	ND
Gillette Elementary	12/29/2016	1/6/2017	759-3	Outside Nurse Office-WC-1st	2.00
Gillette Elementary	12/29/2016	1/6/2017	759-4	Outside Library-WC-1st Draw	ND
Gillette Elementary	12/29/2016	1/6/2017	759-5	Outside Rm #8-1st Draw	35.00
Gillette Elementary	12/29/2016	1/6/2017	759-6	Room #8-S/F	4.00
Gillette Elementary	12/29/2016	1/6/2017	759-7	Room #9-S/F	2.00
Gillette Elementary	12/29/2016	1/6/2017	759-8	Room #10-S/F	4.00
Gillette Elementary	12/29/2016	1/6/2017	759-9	Room #11-S/F	230.00
Gillette Elementary	12/29/2016	1/6/2017	759-10	Room #12-S/F	5.00
Gillette Elementary	12/29/2016	1/7/2017	759-13	Room #16-S/F	ND
Gillette Elementary	12/29/2016	1/7/2017	759-14	Faculty Rm-S	ND
Gillette Elementary	12/29/2016	1/7/2017	759-15	Outside Rm #19-WC-Lft-1st	ND
Gillette Elementary	12/29/2016	1/7/2017	759-16	Outside Rm #19-WC-Rgt-1st	ND
Gillette Elementary	12/29/2016	1/7/2017	759-17	Room #19-S/F-1st Draw	ND
Gillette Elementary	12/29/2016	1/7/2017	759-18	Room #18-S/F-1st Draw	ND
Gillette Elementary	12/29/2016	1/7/2017	759-19	Admin Kitchen-S-1st Draw	ND
Gillette Elementary	12/29/2016	1/7/2017	759-20	QAQC-Sun Rm-S-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-1	Outside Main Office-WC-1st	5.00
Millington Elementary	12/29/2016	1/6/2017	91-3	Gym-WC-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-4	Outside Rm #13-Lft-WC-1st	ND
Millington Elementary	12/29/2016	1/6/2017	91-5	Outside Rm #13-Middle-WC-	ND
Millington Elementary	12/29/2016	1/9/2017	91-6	Outside Rm #13-Rgt-WC-1st	ND
Millington Elementary	12/29/2016	1/9/2017	91-7	Room #8-S/F-1st Draw	10.00
Millington Elementary	12/29/2016	1/9/2017	91-8	Room #7-Lft-1st Draw	7.00
Millington Elementary	12/29/2016	1/9/2017	91-9	Room #7-Rgt-1st Draw	2.00
Millington Elementary	12/29/2016	1/9/2017	91-10	Room #6-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/7/2017	91-11	Room #5-S/F-1st Draw	61.00
Millington Elementary	12/29/2016	1/9/2017	91-12	Outside Rm #4-WF-1st Draw	30.00
Millington Elementary	12/29/2016	1/9/2017	91-13	Room #2-S/F-1st Draw	28.00
Millington Elementary	12/29/2016	1/9/2017	91-14	Faculty Rm-S-1st Draw	1.00
Millington Elementary	12/29/2016	1/9/2017	91-15	Outside Teachers Lounge-W	ND
Millington Elementary	12/29/2016	1/9/2017	91-16	Room #35-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/9/2017	91-17	Room #34-S/F-1st Draw	2.00
Millington Elementary	12/29/2016	1/9/2017	91-18	Room #31-S/F-1st Draw	2.00

Long Hill TWP Public School Water Sampling All Results

ND=None Detected

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Millington Elementary	12/29/2016	1/9/2017	91-19	Room #30-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/9/2017	91-20	Room #29-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/9/2017	91-21	Room #28-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/9/2017	91-22	Room #27-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/9/2017	91-23	Room #26-S/F-1st Draw	1.00
Millington Elementary	12/29/2016	1/9/2017	91-25	Room #24-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/9/2017	91-26	Room #23-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-27	Room #22-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-28	Room #21-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-29	Room #20-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-30	Room #19-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-31	Special Services-S-1st Draw	2.00
Millington Elementary	12/29/2016	1/6/2017	91-32	Room #18-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-33	Room #15-S/F-1st Draw	ND
Millington Elementary	12/29/2016	1/6/2017	91-34	QAQC-Sun Rm-S-1st Draw	ND
Central Middle	12/29/2017	1/6/2017	90-1	Outside Guidance Office-WC	3.00
Central Middle	12/29/2017	1/6/2017	90-2	Nurse Office-NS-1st Draw	2.00
Central Middle	12/29/2017	1/6/2017	90-3	H E #1-EC-1st Draw	60.00
Central Middle	12/29/2017	1/6/2017	90-4	H E #2-EC-1st Draw	4.00
Central Middle	12/29/2017	1/6/2017	90-5	H E #3-EC-1st Draw	27.00
Central Middle	12/29/2017	1/6/2017	90-6	H E #4-EC-1st Draw	2.00
Central Middle	12/29/2017	1/6/2017	90-7	H E #5-EC-1st Draw	45.00
Central Middle	12/29/2017	1/6/2017	90-8	Room #35-S-1st Draw	3.00
Central Middle	12/29/2017	1/6/2017	90-9	Outside Library-Lft-WC-1st D	1.00
Central Middle	12/29/2017	1/6/2017	90-11	Outside Music Rm-Lft-WC-1st	ND
Central Middle	12/29/2017	1/6/2017	90-12	Outside Music Rm-Rgt-WC-1st	ND
Central Middle	12/29/2017	1/6/2017	90-13	Boys Locker Rm-Lft-WC-1st	ND
Central Middle	12/29/2017	1/6/2017	90-14	Boys Locker Rm-Rgt-WC-1st	ND
Central Middle	12/29/2017	1/6/2017	90-15	Outside Rm #3-WC-1st Draw	4.00
Central Middle	12/29/2017	1/6/2017	90-16	Outside Rm #2-WC-1st Draw	ND
Central Middle	12/29/2017	1/6/2017	90-17	Outside Rm #13-WC-1st Dra	1.00
Central Middle	12/29/2017	1/6/2017	90-19	Outside Rm #18-Lft-WC-1st	ND
Central Middle	12/29/2017	1/6/2017	90-21	Outside Rm #24-Lft-WC-1st	1.00
Central Middle	12/29/2017	1/6/2017	90-22	Outside Rm #24-Rgt-WC-1st	2.00
Central Middle	12/29/2017	1/6/2017	90-23	Teachers Rm-S-1st Draw	ND

Long Hill TWP Public School Water Sampling All Results
ND=None Detected

Building	DateCollected	AnalysisDate	Sample ID	Sample Description	Concentration (ppb)
Central Middle	12/29/2017	1/6/2017	90-24	Outside Rm #11-WC-1st Draw	ND
Central Middle	12/29/2017	1/6/2017	90-25	Girls Locker Rm-Lft-1st Draw	ND
Central Middle	12/29/2017	1/6/2017	90-26	Girls Locker Rm-Rgt-1st Draw	ND
Central Middle	12/29/2017	1/6/2017	90-27	QAQC Sun Rm-1st Draw	ND